

# **Preliminary Evaluation of Wastewater Disposal Capacity: Hazelett – Bayside Parcel Colchester, Vermont**

**Craig Heindel, C.P.G.  
Senior Hydrogeologist,  
Waite-Heindel  
Envir. Mgmt.  
Burlington, VT**



## **CONCLUSION:**

- **Capacity for 100,000 – 120,000 gpd is likely available and permittable;**


## **CONCLUSION:**

- Capacity for 100,000 – 120,000 gpd  
is likely available and permittable;
- **Tertiary Treatment is required  
for greater than 50,000 gpd;**

## **CONCLUSION:**

- Capacity for 100,000 – 120,000 gpd is likely available and permittable;
- Tertiary Treatment is required for greater than 50,000 gpd;
- **Several unknown factors would need to be evaluated, for confirmation.**






Parcels, Topo [ft. above sea level], orthophoto from VCGL.

Bayside Hazelett Parcel

SOILS and GROUNDWATER DATA  
on NEARBY PARCELS



**WH** WAITE HEINDEL  
Environmental Management



## **VT's INDIRECT DISCHARGE REGULATIONS:**

[Pertain to land-based WW disposal of greater than 6,500 gpd]

➤ **Three independent capacities must be evaluated:**

**1. Sufficient application area [horizontal];**

## **VT's INDIRECT DISCHARGE REGULATIONS:**

### **➤ Three independent capacities must be evaluated:**

- 1. Sufficient application area [horizontal];**
- 2. Sufficient vertical room for induced groundwater mound [maintain min. 3.0-ft. unsaturated zone below infiltrative surface];**

# **VT's INDIRECT DISCHARGE REGULATIONS:**

- **Three independent capacities must be evaluated:**
  - 1. Sufficient application area [horizontal];**
  - 2. Sufficient vertical room for induced groundwater mound [maintain min. 3.0-ft. unsaturated zone below infiltrative surface];**
  - 3. Compliance with “Aquatic Permitting Criteria” [provides presumption of compliance with Vermont Surface Water Quality Standards].**




# **1. Sufficient Application Area [Horizontal Area]:**

**ADEQUATE FOR 100,000 – 120,000 GPD**

- **By Drip Dispersal; or**
- **By Conventional Leachfield**

Prelim. Eval. WW Disposal  
Hazelett-Bayside Parcel



DRIP  
DISPERSAL



# **PILOT TEST, DRIP DISPERSAL FIELD:**



## PILOT TEST, DRIP DISPERSAL FIELD:



*Perc-Rite® Drip Dispersal System, distributed by Oakson,  
from American Manufacturing:*

- *0.5-in. diameter*
- *Emitters located every 2 ft.*
- *Emitter discharge rate: 0.61 gal/hour, over wide pressure range.*



# **PILOT TEST, DRIP DISPERSAL FIELD:**





## **PILOT TEST, DRIP DISPERSAL FIELD:**



**Prelim. Eval. WW Disposal  
Hazelett-Bayside Parcel**

# **DRIP DISPERSAL INSTALLATIONS In Wooded Areas**



**[Lyme, CT]**




Prelim. Eval. WW Disposal  
Hazelett-Bayside Parcel

# Woods of Hazelett-Bayside Parcel





Prelim. Eval. WW Disposal  
Hazelett-Bayside Parcel



CONVENTIONAL  
LEACHFIELD

**Prelim. Eval. WW Disposal  
Hazelett-Bayside Parcel**

**CONVENTIONAL  
LEACHFIELD**




## **2. Sufficient Hydrogeologic Capacity [Induced Groundwater Mound]:**

**APPEARS TO BE  
ADEQUATE FOR 100,000 – 120,000 GPD**

- **Based on conservative calculations [see Report];**
  - **AND based on limited data, from  
surrounding properties**





Parcels, Topo [ft. above sea level], orthophoto from VCGL.

Bayside Hazelett Parcel

SOILS and GROUNDWATER DATA  
on NEARBY PARCELS



**WH** WAITE HEINDEL  
Environmental Management



### **3. Compliance with Aquatic Permitting Criteria [meet VT Surface Water Quality Standards]:**

**APPEARS LIKELY,  
for 100,000 – 120,000 GPD**

### **3. Compliance with Aquatic Permitting Criteria [meet VT Surface Water Quality Standards]:**

**APPEARS LIKELY,  
for 100,000 – 120,000 GPD**

- Based on Pilot Test conducted on  
site at Bromley Resort with  
similar conditions [deep sands & gravels]**

### **3. Compliance with Aquatic Permitting Criteria [meet VT Surface Water Quality Standards]:**

**APPEARS LIKELY,**

**for 100,000 – 120,000 GPD**

- **Based on Pilot Test conducted on  
site at Bromley Resort with  
similar conditions [deep sands & gravels]**

**CRITICAL NUTRIENTS are toughest hurdle:**

- **Not increase Total Diss. P by more than 0.001 mg/L;**
- **Not increase Nitrate Nitrogen above 2.0 mg/L.**



### **3. Compliance with Aquatic Permitting Criteria [meet VT Surface Water Quality Standards]:**

**APPEARS LIKELY,  
for 100,000 – 120,000 GPD**

- **Not increase Total Diss. Phosphorus by more than 0.001 mg/L;**
  - **Not increase Nitrate Nitrogen above 2.0 mg/L.**
- **Compliance Point: in Groundwater 300 ft. down-gradient.**
  - **SO: Needs Site-Specific confirmation  
AND  
Tertiary Treatment**

## Tertiary Treatment, Per Indirect Discharge Rules:

Parameter	Monthly Average Mg/L	Daily Maximum Mg/L
Biological Oxygen Demand [5-day]	10	18
Total Suspended Solids	10	18
Total Dissolved Phosphorus	0.5	1.0
Total Kjeldahl Nitrogen	5	10
Ammonia [as N]	1	2.0
Nitrate Nitrogen	5	10

## Treatment Levels, Per Indirect Discharge Rules:

**TABLE #12: MINIMUM SEWAGE TREATMENT REQUIREMENTS BASED ON DESIGN CAPACITY AND DISPOSAL METHOD**

Design Capacity (gallons per day)	Disposal Method	Minimum Treatment Level Required
6,500 - 30,000	Leachfield	Primary (Septic tank)
30,001 - 50,000	Leachfield	Secondary + <sup>(1)</sup>
50,001 and greater	Leachfield	Tertiary
6,500 and greater	Sprayfield	Secondary
<sup>(1)</sup> Secondary 'plus' treatment level from recirculating sand / textile filters. See Table #13.		

# Treatment Levels, Per Indirect Discharge Rules:

**TABLE #13: EFFLUENT LIMITATIONS FOR EACH TREATMENT LEVEL**

	Effluent Limitation (in mg/L) by Treatment Level			
Parameter	Septic Tank	Secondary	Secondary + <sup>(1)</sup>	Tertiary
Biochemical Oxygen Demand (5-Day)	N/A	30 <sup>(2)</sup>	15 <sup>(3)</sup>	10 <sup>(4)</sup>
Total Suspended Solids	N/A	30 <sup>(2)</sup>	15 <sup>(3)</sup>	10 <sup>(4)</sup>
Total Dissolved Phosphorus	N/A	N/A	N/A	0.5 <sup>(5)</sup>
Total Kjeldahl Nitrogen	N/A	N/A	N/A	5 <sup>(6)</sup>
Ammonia (as N)	N/A	N/A	N/A	1 <sup>(7)</sup>
Nitrate nitrogen	N/A	N/A	N/A	5 <sup>(8)</sup>
Total Nitrogen (as N)	N/A	N/A	N/A	N/A


## **Treatment Levels: Avoid Tertiary Treatment?**

- **Wastewater Flows below 50,000 gpd;**
- **May not meet Aquatic Permitting Criteria,  
particularly Phosphorus removal  
[not increase TDP in groundwater  
by more than 0.001 mg/L]**



Prelim. Eval. WW Disposal  
Hazelett-Bayside Parcel

Slope Stability Issue,  
East Lakeshore Drive





**Prelim. Eval. WW Disposal  
Hazelett-Bayside Parcel**

## **Slope Stability Issue, East Lakeshore Drive**



## **CONCLUSION:**

- **Capacity for 100,000 – 120,000 gpd is likely available and permittable;**
- **Tertiary Treatment is required for greater than 50,000 gpd;**
- **Several unknown factors would need to be evaluated, for confirmation.**



## **Next Steps:**

- 1. Evaluate the potential risk of large-scale WW disposal on the slope stability between East Lakeshore Drive and Malletts Bay.**
- 2. Evaluate soil characteristics, groundwater depths, groundwater flow directions -- by borings and monitoring wells throughout and around the parcel.**
- 3. Water level monitoring in the monitoring wells through the seasonal high water table period [March 1 – May 31].**

## **Next Steps:**

1. Evaluate the potential risk of large-scale WW disposal on the slope stability between East Lakeshore Drive and Mallet's Bay.
2. Evaluate soil characteristics, groundwater depths, groundwater flow directions  
-- by borings and monitoring wells throughout and around the parcel.
3. Water level monitoring in the monitoring wells  
through the seasonal high water table period [March 1 – May 31].

**Further evaluations would then be considered, after these initial steps are taken:**

- **Determine groundwater flow directions,**
- **Determine compliance point[s] for Indirect Discharge Permit,**
- **Conduct pilot test to document nutrient removal.**

**Prelim. Eval. WW Disposal  
Hazelett-Bayside Parcel**

**Preliminary Evaluation  
of Wastewater Disposal Capacity:  
Hazelett – Bayside Parcel  
Colchester, Vermont**

**Questions?**

**Craig Heindel, C.P.G.  
Senior Hydrogeologist**